

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62340
Work Order: 50400068_01

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:18
Sample Point:	AND-2HALL-BF	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62341
Work Order: 50400068_02

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:18
Sample Point:	AND-2HALL-BF-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62342
Work Order: 50400068_03

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:17
Sample Point:	AND-2HALL-WC	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62343
Work Order: 50400068_04

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:17
Sample Point:	AND-2HALL-WC-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62344
Work Order: 50400068_05

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:22
Sample Point:	AND-KIT-KF	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.006	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62345
Work Order: 50400068_06

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:22
Sample Point:	AND-KIT-KF-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.003	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62346
Work Order: 50400068_07

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:24
Sample Point:	AND-301-NS	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62347
Work Order: 50400068_08

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:24
Sample Point:	AND-301-NS-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62348
Work Order: 50400068_09

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:25
Sample Point:	AND-305-TL	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62349
Work Order: 50400068_10

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:25
Sample Point:	AND-305-TL-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62350
Work Order: 50400068_11

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:28
Sample Point:	AND-211-B	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62351
Work Order: 50400068_12

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:28
Sample Point:	AND-211-B-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62352
Work Order: 50400068_13

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:29
Sample Point:	AND-2HALL-2-WC	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62353
Work Order: 50400068_14

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:29
Sample Point:	AND-2HALL-2-WC-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62354
Work Order: 50400068_15

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:32
Sample Point:	AND-207-B	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62355
Work Order: 50400068_16

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:32
Sample Point:	AND-207-B-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62356
Work Order: 50400068_17

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:37
Sample Point:	AND-111-B	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62357
Work Order: 50400068_18

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:37
Sample Point:	AND-111-B-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62358
Work Order: 50400068_19

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:40
Sample Point:	AND-1HALL-WC	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62359
Work Order: 50400068_20

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:40
Sample Point:	AND-1HALL-WC-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62360
Work Order: 50400068_21

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:41
Sample Point:	AND-126-B	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62361
Work Order: 50400068_22

System Name/Owner:	00336-ANDREWS ELEMENTARY SCHOO	WSSN/Pool ID:	
Collection Address:	200 S DOUGLAS AVE,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:41
Sample Point:	AND-126-B-F	Date Received:	04/01/2025 13:37
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane