

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62464
Work Order: 50400094_01

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:14
Sample Point:	MS-PACHALL-BF	Date Received:	04/01/2025 14:18
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62465
Work Order: 50400094_02

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:14
Sample Point:	MS-PACHALL-BF-F	Date Received:	04/01/2025 14:18
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62466
Work Order: 50400094_03

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:13
Sample Point:	MS-PACHALL-WC	Date Received:	04/01/2025 14:18
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62467
Work Order: 50400094_04

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:13
Sample Point:	MS-PACHALL-WC-F	Date Received:	04/01/2025 14:18
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62468
Work Order: 50400094_05

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:16
Sample Point:	MS-CAF-WC	Date Received:	04/01/2025 14:18
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.070	mg/L	0.001	04/04/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62469
Work Order: 50400094_06

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:16
Sample Point:	MS-CAF-WC-F	Date Received:	04/01/2025 14:18
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.072	mg/L	0.001	04/04/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62470
Work Order: 50400094_07

System Name/Owner: 06272-THREE RIVERS MIDDLE SCHO
Collection Address: 1101 JEFFERSON ST,THREE RIVERS
Collected By: ANDY WERT
Township/Well#/Section: //
County: St Joseph
Sample Point: MS-KIT-KK
Water System: Other

WSSN/Pool ID:
Source: Other
Site Code: WIIN
Collector: Other
Date Collected: 03/28/2025 10:18
Date Received: 04/01/2025 14:18
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.004	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62471
Work Order: 50400094_08

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:18
Sample Point:	MS-KIT-KK-F	Date Received:	04/01/2025 14:18
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.008	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62472
Work Order: 50400094_09

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:19
Sample Point:	MS-KIT-2-KK	Date Received:	04/01/2025 14:18
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.005	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62473
Work Order: 50400094_10

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:19
Sample Point:	MS-KIT-2-KK-F	Date Received:	04/01/2025 14:18
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62474
Work Order: 50400094_11

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:21
Sample Point:	MS-KIT-KF	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.012	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62475
Work Order: 50400094_12

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:21
Sample Point:	MS-KIT-KF-F	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.002	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62476
Work Order: 50400094_13

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:26
Sample Point:	MS-PACHALL-3-WC	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.003	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62477
Work Order: 50400094_14

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:26
Sample Point:	MS-PACHALL-3-WC-F	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.005	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62478
Work Order: 50400094_15

System Name/Owner: 06272-THREE RIVERS MIDDLE SCHO
Collection Address: 1101 JEFFERSON ST,THREE RIVERS
Collected By: ANDY WERT
Township/Well#/Section: //
County: St Joseph
Sample Point: MS-TL-TL
Water System: Other

WSSN/Pool ID:
Source: Other
Site Code: WIIN
Collector: Other
Date Collected: 03/28/2025 10:28
Date Received: 04/01/2025 14:19
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.002	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161**

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62479
Work Order: 50400094_16

System Name/Owner: 06272-THREE RIVERS MIDDLE SCHO
Collection Address: 1101 JEFFERSON ST,THREE RIVERS
Collected By: ANDY WERT
Township/Well#/Section: //
County: St Joseph
Sample Point: MS-TL-TL-F
Water System: Other

WSSN/Pool ID:
Source: Other
Site Code: WIIN
Collector: Other
Date Collected: 03/28/2025 10:28
Date Received: 04/01/2025 14:19
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62480
Work Order: 50400094_17

System Name/Owner: 06272-THREE RIVERS MIDDLE SCHO
Collection Address: 1101 JEFFERSON ST,THREE RIVERS
Collected By: ANDY WERT
Township/Well#/Section: //
County: St Joseph
Sample Point: MS-1HALL-BF
Water System: Other

WSSN/Pool ID:
Source: Other
Site Code: WIIN
Collector: Other
Date Collected: 03/28/2025 10:32
Date Received: 04/01/2025 14:19
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62481
Work Order: 50400094_18

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:32
Sample Point:	MS-1HALL-BF-F	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62482
Work Order: 50400094_19

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:33
Sample Point:	MS-1HALL-WC	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62483
Work Order: 50400094_20

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:33
Sample Point:	MS-1HALL-WC-F	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62484
Work Order: 50400094_21

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:36
Sample Point:	MS-1HALL-2-BF	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62485
Work Order: 50400094_22

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:36
Sample Point:	MS-1HALL-2-BF-F	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62486
Work Order: 50400094_23

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:35
Sample Point:	MS-1HALL-2-WC-F	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U .S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE
EGLE-DWEHD-CWSS-LCU
PO BOX 30817
LANSING MI 48909-8311

Sample ID: LL62487
Work Order: 50400094_24

System Name/Owner:	06272-THREE RIVERS MIDDLE SCHO	WSSN/Pool ID:	
Collection Address:	1101 JEFFERSON ST,THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:35
Sample Point:	MS-1HALL-2-WC	Date Received:	04/01/2025 14:19
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Branch-Hillsdale-St. Joseph Health Dept
1110 Hill St.
Three Rivers, MI 49093
269 273-2161

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane