

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62438**  
**Work Order: 50400093\_01**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-102-NS  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:32  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.001	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62439**  
**Work Order: 50400093\_02**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-102-NS-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:32  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62440**  
**Work Order: 50400093\_03**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-103-TL  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:33  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.001	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62441**  
**Work Order: 50400093\_04**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD,THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-103-TL-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:33  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62442**  
**Work Order: 50400093\_05**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-HALL-BF  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:38  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62443**  
**Work Order: 50400093\_06**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-HALL-BF-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:38  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62444**  
**Work Order: 50400093\_07**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-HALL-WC  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:36  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62445**  
**Work Order: 50400093\_08**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-HALL-WC-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:36  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane



### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62446**  
**Work Order: 50400093\_09**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-KIT-KF  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:41  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.002	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62447**  
**Work Order: 50400093\_10**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-KIT-KF-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:41  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62448**  
**Work Order: 50400093\_11**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-KHALL-WC  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:44  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62449**  
**Work Order: 50400093\_12**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-KHALL-WC-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:44  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62450**  
**Work Order: 50400093\_13**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-107-B  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:48  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.001	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62451**  
**Work Order: 50400093\_14**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-107-B-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:48  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62452**  
**Work Order: 50400093\_15**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-206-B  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:52  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62453**  
**Work Order: 50400093\_16**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-206-B-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:52  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane



### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62454**  
**Work Order: 50400093\_17**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-201-B  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:55  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62455**  
**Work Order: 50400093\_18**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-201-B-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:55  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62456**  
**Work Order: 50400093\_19**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-207-B-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:58  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62457**  
**Work Order: 50400093\_20**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-207-B  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 08:58  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.002	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62458**  
**Work Order: 50400093\_21**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-210-B  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 09:01  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62459**  
**Work Order: 50400093\_22**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-210-B-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 09:01  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62460**  
**Work Order: 50400093\_23**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-HALL-2-WC  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 09:04  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62461**  
**Work Order: 50400093\_24**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-HALL-2-WC-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 09:04  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane



Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62462**  
**Work Order: 50400093\_25**

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-3HALL-2-WC-F  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 09:11  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID:** LL62463  
**Work Order:** 50400093\_26

System Name/Owner: 05336-PARK ELEMENTARY  
Collection Address: 53806 WILBUR RD, THREE RIVERS  
Collected By: ANDY WERT  
Township/Well#/Section: //  
County: St Joseph  
Sample Point: PAR-3HALL-2-WC  
Water System: Other

WSSN/Pool ID:  
Source: Other  
Site Code: WIIN  
Collector: Other  
Date Collected: 03/28/2025 09:11  
Date Received: 04/01/2025 14:09  
Purpose: Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane